



*alpha*

---

Alpha Analytical Laboratories, Inc.

email: [clientservices@alpha-labs.com](mailto:clientservices@alpha-labs.com)

Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

10 January 2020

Volcano CSD

Attn: George Barnes

P O Box 72

Volcano, CA 95689

RE: Routine - Coliform

Work Order: 19L3956

Enclosed are the results of analyses for samples received by the laboratory on 12/30/19 14:00. If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Jeanette L. Poplin For Karen L. Lantz

Project Manager



Alpha Analytical Laboratories, Inc. email: [clientservices@alpha-labs.com](mailto:clientservices@alpha-labs.com)  
Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

Volcano CSD  
P O Box 72  
Volcano, CA 95689

Project Manager: George Barnes  
Project: Routine - Coliform  
Project Number: 0300016

Reported:  
01/10/20 06:32

Bay Area: 262 Rickenbacker Circle | Livermore, CA 94551 | T: 925-828-6226 | F: 925-828-6309 | ELAP# 2728  
Central Valley: 9090 Union Park Way Suite 113 | Elk Grove, CA 95624 | T: 916-686-5190 | F: 916-686-5192 | ELAP# 2922  
North Bay: 110 Liberty Street | Petaluma, CA 94952 | T: 707-769-3128 | F: 707-769-8093 | ELAP# 2303  
San Diego Service Center: 2722 Loker Avenue West Suite A | Carlsbad, CA 92010 | T: 760-930-2555 | F: 760-930-2510

#### ANALYTICAL REPORT FOR SAMPLES

Sample ID	Laboratory ID	Matrix	Date Sampled	Date Received
Well #1	19L3956-01	Water	12/30/19 11:50	12/30/19 14:00
Well #2	19L3956-02	Water	12/30/19 11:50	12/30/19 14:00
Cleveland Tunnel	19L3956-03	Water	12/30/19 11:45	12/30/19 14:00



Alpha Analytical Laboratories, Inc. email: [clientservices@alpha-labs.com](mailto:clientservices@alpha-labs.com)  
 Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

Volcano CSD P O Box 72 Volcano, CA 95689	Project Manager: George Barnes Project: Routine - Coliform Project Number: 0300016	Reported: 01/10/20 06:32
--	--	-----------------------------

	Result	Reporting Limit	Dilution	Batch	Prepared	Analyzed	ELAP#	Method	Note	
<b>Well #1 (19L3956-01)</b>										
		<b>Sample Type: Water</b>				<b>Sampled: 12/30/19 11:50</b>				
<b>Microbiological Parameters by APHA Standard Methods</b>										
Total Coliforms	ND MPN/100mL	1.0	1	AA03079	12/30/19 15:00	12/31/19 15:10	2922	SM9223B		
E. Coli	ND MPN/100mL	1.0	1	AA03079	12/30/19 15:00	12/31/19 15:10	2922	SM9223B		
<b>Well #2 (19L3956-02)</b>										
		<b>Sample Type: Water</b>				<b>Sampled: 12/30/19 11:50</b>				
<b>Microbiological Parameters by APHA Standard Methods</b>										
Total Coliforms	ND MPN/100mL	1.0	1	AA03079	12/30/19 15:00	12/31/19 15:10	2922	SM9223B		
E. Coli	ND MPN/100mL	1.0	1	AA03079	12/30/19 15:00	12/31/19 15:10	2922	SM9223B		
<b>Cleveland Tunnel (19L3956-03)</b>										
		<b>Sample Type: Water</b>				<b>Sampled: 12/30/19 11:45</b>				
<b>Microbiological Parameters by APHA Standard Methods</b>										
Total Coliforms	<b>3.0 MPN/100mL</b>	<b>1.0</b>	1	AA03079	12/30/19 15:00	12/31/19 15:10	2922	SM9223B		
E. Coli	ND MPN/100mL	1.0	1	AA03079	12/30/19 15:00	12/31/19 15:10	2922	SM9223B		

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Alpha Analytical Laboratories, Inc. email: [clientservices@alpha-labs.com](mailto:clientservices@alpha-labs.com)  
Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551


Volcano CSD  
P O Box 72  
Volcano, CA 95689

Project Manager: George Barnes  
Project: Routine - Coliform  
Project Number: 0300016

Reported:  
01/10/20 06:32

**Notes and Definitions**

ND Analyte NOT DETECTED at or above the reporting limit  
dry Sample results reported on a dry weight basis  
RPD Relative Percent Difference



**Corporate Laboratory**  
 208 Mason Street, Ukiah CA 95482  
 707-468-0401 F) 707-468-5267  
 email: clientservices@alpha-labs.com

**Bay Area Laboratory**  
 6398 Dougherty Rd #35, Dublin CA 94568  
 925-828-6226 F) 925-828-6309

# Chain of Custody - Work Order

Reports and invoices delivered by email in PDF format

**ELAP Certifications**  
 Ukiah 1551 / Dublin 2728 / Elk Grove 2922

**Central Valley Laboratory**  
 9090 Union Park Way #113, Elk Grove CA 95624  
 916-686-5190 F) 916-686-5192

Lab No 19L3956 Pg \_\_\_\_\_ of \_\_\_\_\_

Report to		Invoice to (if different)		Project Information										Signature below authorizes work under terms stated on reverse side.																			
Company: <b>Volcano CSD</b>		Contact:		Project ID: Routine-Coliform										Analysis Request  TAT Standard 10 days <input type="radio"/> RUSH: 5 days <input checked="" type="checkbox"/> 48 hours <input type="checkbox"/> Other: <input type="radio"/> ___ days <input type="radio"/> Lab preapproval required																			
Attn: <b>George Barnes</b>		Email address:		Project No: 0300016-Raw																				Temp upon Receipt °C Ukiah temp:  Dublin temp:  Elk Grove temp: 47.2									
Address: PO Box 72 Volcano, CA 95689		Address:		PO Number:																													
Phone/Fax: 209-296-4888		Phone/Fax:		Internal Lab Use:																				Total Number of Containers per Sample ID <b>CV - TCEC Quantitray</b>									
Email Address:																																	
Field Sampler - Printed Name & Signature: <i>George Barnes</i>				Container		Preservative				Matrix																							
Sample Identification		Sampling		40ml Vial	Poly	Glass	Sleeve	Other	HCl	HNO3	NaOH	Na2S2O3	None	Water	Soil	Other																	
		Date	Time																														
Well #1	12-30	11:50		x								x		x			1	x															
Well #2	12-30	11:50		x								x		x			1	x															
Cleveland Tunnel	12-30	11:45		x								x		x			1	x															
Relinquished by <i>George Barnes</i>				Received by <i>[Signature]</i>				Date	Time	CDPH Write On EDT Transmission? <input checked="" type="radio"/> Yes <input type="radio"/> No																							
								12-30-19	1:30	State System Number: 0300016																							
								12-30-19	1:40	If "Y" please enter the Source Number(s) in the column above																							
								Mail Hardcopy to DDW-? <input type="radio"/> Yes <input type="radio"/> No																									
								Hardcopy to DDW attn:																									
								Travel and Site Time:	Mileage:	Misc. Supplies:																							

